



CVE-2013-0663

- MITRE
- NVD
- CVE.ORG
- JSON API
- Print: PDF

Summary

CVE	CVE-2013-0663
State	PUBLISHED
Assigner	icscert
Source Priority	CVE Program / NVD first with legacy fallback
Published	2013-04-04 11:58:48 UTC
Updated	2026-04-29 01:13:23 UTC
Description	Cross-site request forgery (CSRF) vulnerability on the Schneider Electric Quantum 140NOE77111, 140NOE77101, and 140NOE77102

Risk And Classification

Primary CVSS: v2.0 6.8 from nvd@nist.gov

AV:N/AC:M/Au:N/C:P/I:P/A:P

Problem Types: CWE-352 | n/a

CVSS v2.0 Breakdown

Access Vector

Network

Access Complexity

Medium

Authentication

None

Confidentiality

Partial

Integrity

Partial

Availability

Partial

AV:N/AC:M/Au:N/C:P/I:P/A:P

NVD Known Affected Configurations (CPE 2.3)

Type	Vendor	Product	Version	Update	Edition	Language
Hardware	Schneider-electric	Modicon M340	bmxnoc0401	All	All	All

Hardware	Schneider-electric	Modicon M340	bmxnoe0100x	All	All	All
Hardware	Schneider-electric	Modicon M340	bmxnoe011xx	All	All	All
Hardware	Schneider-electric	Modicon Premium	tsxety4103	All	All	All
Hardware	Schneider-electric	Modicon Premium	tsxety5103	All	All	All
Hardware	Schneider-electric	Modicon Premium	tsxwmy100	All	All	All
Hardware	Schneider-electric	Modicon Quantum Plc	140noe77101	All	All	All
Hardware	Schneider-electric	Modicon Quantum Plc	140noe77111	All	All	All
Hardware	Schneider-electric	Modicon Quantum Plc	140nwm10000	All	All	All

Vendor Declared Affected Products				
Source	Vendor	Product	Version	Platforms
CNA	Na	N/a	affected n/a	Not specified

References		
Reference	Source	Link
404 - File Not Found CISA	af854a3a-2127-422b-91ae-364da2661108	ics-cert.us-
Product Documentation & Software downloads Schneider Electric	af854a3a-2127-422b-91ae-364da2661108	www.schne
Schneider Electric PLCs - Cross-Site Request Forgery - Windows webapps Exploit	af854a3a-2127-422b-91ae-364da2661108	www.explo
Documents & Downloads	af854a3a-2127-422b-91ae-364da2661108	www.schne
CVE Program record	CVE.ORG	www.cve.o
NVD vulnerability detail	NVD	nvd.nist.go

No vendor comments have been submitted for this CVE.

Legacy QID Mappings
590485 Schneider Electric PLCs (Update B) Multiple Vulnerabilities (ICSA-13-077-01B)