



CVE-2013-6143

Published on: 01/31/2014 12:00:00 AM UTC

Last Modified on: 03/23/2021 11:28:39 PM UTC

CVE-2013-6143

Source: Mitre

Source: NIST

CVE.ORG

Print: PDF



Certain versions of [Telvent Sage 3030 Firmware](#) from [Schneider-electric](#) contain the following vulnerability:

The Schneider Electric Telvent SAGE 3030 RTU with firmware C3413-500-001D3_P4 and C3413-500-001F0_PB allows remote attackers to cause a denial of service (temporary outage and CPU consumption) via malformed DNP3 traffic.

CVE-2013-6143 has been assigned by ics-cert@hq.dhs.gov to track the vulnerability

CVSS2 Score: **5 - MEDIUM**

Access
Vector

NETWORK

Access
Complexity

LOW

Authentication

NONE

Confidentiality
Impact

NONE

Integrity
Impact

NONE

Availability
Impact

PARTIAL

CVE References

Description

Schneider Electric Telvent SAGE RTU DNP3 Improper Input Validation Vulnerability | ICS-CERT

Tags

[US Government Resource](#)
[ics-cert.us-cert.gov](#)
[text/html](#)

Link

[MISC ics-cert.us-cert.gov/advisories/ICSA-14-006-01](#)

By selecting these links, you may be leaving CVEreport webspace. We have provided these links to other websites because they may have information that would be of interest to you. No inferences should be drawn on account of other sites being referenced, or not, from this page. There may be other websites that are more appropriate for your purpose. CVEreport does not necessarily endorse the views expressed, or concur with the facts presented on these sites. Further, CVEreport does not endorse any commercial products that may be mentioned on these sites. Please address comments about any linked pages to comment@cve.report.

There are currently no QIDs associated with this CVE

Known Affected Configurations (CPE V2.3)

Type	Vendor	Product	Version	Update	Edition	Language
Operating System	Schneider-electric	Telvent Sage 3030 Firmware	c3413-500-001d3_p4	All	All	All
Operating System	Schneider-electric	Telvent Sage 3030 Firmware	c3413-500-001f0_pb	All	All	All
Operating System	Schneider-electric	Telvent Sage 3030 Firmware	c3413-500-001d3_p4	All	All	All
Operating System	Schneider-electric	Telvent Sage 3030 Firmware	c3413-500-001f0_pb	All	All	All
cpe:2.3:o:schneider-electric:telvent_sage_3030_firmware:c3413-500-001d3_p4:*****:.*:						
cpe:2.3:o:schneider-electric:telvent_sage_3030_firmware:c3413-500-001f0_pb:*****:.*:						
cpe:2.3:o:schneider-electric:telvent_sage_3030_firmware:c3413-500-001d3_p4:*****:.*:						
cpe:2.3:o:schneider-electric:telvent_sage_3030_firmware:c3413-500-001f0_pb:*****:.*:						
No vendor comments have been submitted for this CVE						
← Previous ID				Next ID →		