



CVE-2014-0761

Published on: 08/27/2014 12:00:00 AM UTC

Last Modified on: 03/23/2021 11:25:57 PM UTC


CVE-2014-0761

Source: Mitre

Source: NIST

CVE.ORG

Print: PDF



Certain versions of [Epaq-9410 Substation Gateway](#) from [Qeiinc](#) contain the following vulnerability:

The DNP3 driver in CG Automation ePAQ-9410 Substation Gateway allows remote attackers to cause a denial of service (infinite loop or process crash) via a crafted TCP packet.

CVE-2014-0761 has been assigned by ics-cert@hq.dhs.gov to track the vulnerability

CVSS2 Score: **7.1 - HIGH**

Access
Vector

Access
Complexity

Authentication

NETWORK

MEDIUM

NONE

Confidentiality
Impact

Integrity
Impact

Availability
Impact

NONE

NONE

COMPLETE

CVE References

Description

Tags

Link

CG Automation Improper Input Validation | ICS-CERT

[US Government Resource](#)

ics-cert.us-cert.gov

[text/html](#)

[MISC](https://www.facebook.com/MISC) ics-cert.us-cert.gov/advisories/ICSA-14-238-01

By selecting these links, you may be leaving CVEreport webspace. We have provided these links to other websites because they may have information that would be of interest to you. No inferences should be drawn on account of other sites being referenced, or not, from this page. There may be other websites that are more appropriate for your purpose. CVEreport does not necessarily endorse the views expressed, or concur with the facts presented on these sites. Further, CVEreport does not endorse any commercial products that may be mentioned on these sites. Please address comments about any linked pages to comment@cve.report.

There are currently no QIDs associated with this CVE

Known Affected Configurations (CPE V2.3)

Type	Vendor	Product	Version	Update	Edition	Language
Hardware 	Qeiinc	Epaq-9410 Substation Gateway	-	All	All	All
Hardware 	Qeiinc	Epaq-9410 Substation Gateway	-	All	All	All
cpe:2.3:h:qeiinc:epaq-9410_substation_gateway:-:*****:						
cpe:2.3:h:qeiinc:epaq-9410_substation_gateway:-:*****:						
No vendor comments have been submitted for this CVE						
← Previous ID			Next ID→			