



Schneider Electric ETG3000 FactoryCast HMI Gateway

Missing Authentication for Critical Function

MITRE

NVD

CVE.ORG

JSON API

Print: PDF

Summary

CVE	CVE-2014-9197
State	PUBLISHED
Assigner	icscert
Source Priority	CVE Program / NVD first with legacy fallback
Published	2015-01-27 19:59:00 UTC
Updated	2026-05-06 22:30:45 UTC
Description	The Schneider Electric ETG3000 FactoryCast HMI Gateway with firmware before 1.60 IR 04 stores rde.jar under the web r

Risk And Classification

Primary CVSS: v2.0 7.8 from nvd@nist.gov

AV:N/AC:L/Au:N/C:C/I:N/A:N

Problem Types: CWE-306 | CWE-284 | CWE-306 CWE-306

Version	Source	Type	Score	Severity	Vector
2.0	nvd@nist.gov	Primary	7.8		AV:N/AC:L/Au:N/C:C/I:N/A:N
2.0	ics-cert@hq.dhs.gov	Secondary	10		AV:N/AC:L/Au:N/C:C/I:C/A:C
2.0	CNA	CVSS	10		AV:N/AC:L/Au:N/C:C/I:C/A:C

CVSS v2.0 Breakdown

Access Vector

Network

Access Complexity

Low

Authentication

None

Confidentiality

Complete

ntegrity

None

Availability

None

NVD Known Affected Configurations (CPE 2.3)

Type	Vendor	Product	Version	Update	Edition	Language
Operating System	Schneider-electric	Etg3000 Factorycast Hmi Gateway Firmware	1.60.2	All	All	All
Hardware	Schneider-electric	Tsxetg3000	-	All	All	All
Hardware	Schneider-electric	Tsxetg3010	-	All	All	All
Hardware	Schneider-electric	Tsxetg3021	-	All	All	All
Hardware	Schneider-electric	Tsxetg3022	-	All	All	All

Vendor Declared Affected Products

Source	Vendor	Product	Version	Platforms
CNA	Schneider Electric	ETG3000 FactoryCast HMI Gateway	affected TSXETG3000	Not specified
CNA	Schneider Electric	ETG3000 FactoryCast HMI Gateway	affected TSXETG3010	Not specified
CNA	Schneider Electric	ETG3000 FactoryCast HMI Gateway	affected TSXETG3021	Not specified
CNA	Schneider Electric	ETG3000 FactoryCast HMI Gateway	affected TSXETG3022	Not specified

References

Reference	Source	Link
Schneider Electric ETG3000 FactoryCast HMI Gateway Vulnerabilities ICS-CERT	af854a3a-2127-422b-91ae-364da2661108	ics-cert.us-
www.cisa.gov/news-events/ics-advisories/icsa-15-020-02	ics-cert@hq.dhs.gov	www.cisa.g
CVE Program record	CVE.ORG	www.cve.o
NVD vulnerability detail	NVD	nvd.nist.go

Vendor Comments And Credit

Discovery Credit

CNA: Narendra Shinde of Qualys Security (en)

Additional Advisory Data

Solutions

CNA: Schneider Electric has produced an updated firmware, labelled V1.60 IR 04. This firmware release moves the jar files directory in a secure area. The new firmware also includes the ability to disable the FTP server. This updated firmware can be downloaded at: <http://www.schneider-electric.com/download/WW/EN/details/681790255-TSXETG30xx-V160-IR4/?showAsIframe...> <http://www.schneider-electric.com/download/WW/EN/details/681790255-TSXETG30xx-V160-IR4/>

Workarounds

CNA: Schneider Electric recommends the FTP server be deactivated when not needed. The firmware update does not remove the hard-coded credentials. Narendra Shinde also found that configuration files were accessible using default credentials. Schneider Electric recommends users change the default login credentials. This will protect configuration files from unauthorized access.

Legacy QID Mappings

[590491](#) Schneider Electric ETG3000 FactoryCast HMI Gateway Multiple Vulnerabilities (ICSA-15-020-02)

© [CVE.report](#) 2026 |

Use of this information constitutes acceptance for use in an AS IS condition. There are NO warranties, implied or otherwise, with regard to this information or its use. Any use of this information is at the user's risk. It is the responsibility of user to evaluate the accuracy, completeness or usefulness of any information, opinion, advice or other content. EACH USER WILL BE SOLELY RESPONSIBLE FOR ANY consequences of his or her direct or indirect use of this web site. ALL WARRANTIES OF ANY KIND ARE EXPRESSLY DISCLAIMED. This site will NOT BE LIABLE FOR ANY DIRECT, INDIRECT or any other kind of loss.

CVE, CWE, and OVAL are registered trademarks of [The MITRE Corporation](#) and the authoritative source of CVE content is [MITRE's CVE web site](#). This site includes MITRE data granted under the following [license](#).

Free CVE JSON API [cve.report/api](#)

CVE.report and Source URL Uptime Status [status.cve.report](#)