



CVE-2016-4513

[MITRE](#)[NVD](#)[CVE.ORG](#)[Print: PDF](#)

Summary

CVE	CVE-2016-4513
State	PUBLIC
Assigner	ics-cert@hq.dhs.gov
Source Priority	CVE Program / NVD first with legacy fallback
Published	2016-06-26 01:59:00 UTC
Updated	2016-06-28 15:22:00 UTC
Description	Cross-site scripting (XSS) vulnerability in the Schneider Electric PowerLogic PM8ECC module before 2.651 for PowerMeter

Risk And Classification

Problem Types: CWE-79

NVD Known Affected Configurations (CPE 2.3)

Type	Vendor	Product	Version	Update	Edition	Language
Hardware	Schneider-electric	Powerlogic Pm8ecc	-	All	All	All
Hardware	Schneider-electric	Powerlogic Pm8ecc	-	All	All	All
Operating System	Schneider-electric	Powerlogic Pm8ecc Firmware	All	All	All	All

References

Reference	Source	Link	Tags
Schneider Electric PowerLogic PM8ECC Cross-site Scripting Vulnerability ICS-CERT	MISC	ics-cert.us-cert.gov	Third Party Adviso
CVE Program record	CVE.ORG	www.cve.org	canonical
NVD vulnerability detail	NVD	nvd.nist.gov	canonical, analysi

No vendor comments have been submitted for this CVE.

Legacy QID Mappings

[590490](#) Schneider Electric PowerLogic PM8ECC Cross-Site Scripting (XSS) Vulnerability Vulnerability (ICSA-16-173-02)

this information or its use. Any use of this information is at the user's risk. It is the responsibility of user to evaluate the accuracy, completeness or usefulness of any information, opinion, advice or other content. EACH USER WILL BE SOLELY RESPONSIBLE FOR ANY consequences of his or her direct or indirect use of this web site. ALL WARRANTIES OF ANY KIND ARE EXPRESSLY DISCLAIMED. This site will NOT BE LIABLE FOR ANY DIRECT, INDIRECT or any other kind of loss.

CVE, CWE, and OVAL are registered trademarks of [The MITRE Corporation](#) and the authoritative source of CVE content is [MITRE's CVE web site](#). This site includes MITRE data granted under the following [license](#).

CVE.report and Source URL Uptime Status [status.cve.report](#)