



CVE-2017-12731

[MITRE](#)[NVD](#)[CVE.ORG](#)[Print: PDF !\[\]\(e3f8612927870f2e0f9f5989e6dd3064_img.jpg\)](#)

Summary

CVE	CVE-2017-12731
State	PUBLIC
Assigner	ics-cert@hq.dhs.gov
Source Priority	CVE Program / NVD first with legacy fallback
Published	2017-09-09 01:29:00 UTC
Updated	2019-10-09 23:23:00 UTC
Description	A SQL Injection issue was discovered in OPW Fuel Management Systems SiteSentinel Integra 100, SiteSentinel Integra 500

Risk And Classification

Problem Types: CWE-89

NVD Known Affected Configurations (CPE 2.3)

Type	Vendor	Product	Version	Update	Edition	Language
Hardware	Opwglobal	Sitesentinel Integra 100	-	All	All	All
Hardware	Opwglobal	Sitesentinel Integra 100	-	All	All	All
Operating System	Opwglobal	Sitesentinel Integra 100 Firmware	16q3.1	All	All	All
Operating System	Opwglobal	Sitesentinel Integra 100 Firmware	189	All	All	All
Operating System	Opwglobal	Sitesentinel Integra 100 Firmware	191	All	All	All
Operating System	Opwglobal	Sitesentinel Integra 100 Firmware	195	All	All	All
Operating System	Opwglobal	Sitesentinel Integra 100 Firmware	16q3.1	All	All	All
Operating System	Opwglobal	Sitesentinel Integra 100 Firmware	189	All	All	All
Operating System	Opwglobal	Sitesentinel Integra 100 Firmware	191	All	All	All
Operating System	Opwglobal	Sitesentinel Integra 100 Firmware	195	All	All	All
Operating System	Opwglobal	Sitesentinel Integra 100 Firmware	All	All	All	All
Hardware	Opwglobal	Sitesentinel Integra 500	-	All	All	All
Hardware	Opwglobal	Sitesentinel Integra 500	-	All	All	All
Operating System	Opwglobal	Sitesentinel Integra 500 Firmware	16q3.1	All	All	All
Operating System	Opwglobal	Sitesentinel Integra 500 Firmware	189	All	All	All
Operating System	Opwglobal	Sitesentinel Integra 500 Firmware	191	All	All	All
Operating System	Opwglobal	Sitesentinel Integra 500 Firmware	195	All	All	All

Operating System	Opwglobal	Sitesentinel Integra 500 Firmware	16q3.1	All	All	All
Operating System	Opwglobal	Sitesentinel Integra 500 Firmware	189	All	All	All
Operating System	Opwglobal	Sitesentinel Integra 500 Firmware	191	All	All	All
Operating System	Opwglobal	Sitesentinel Integra 500 Firmware	195	All	All	All
Operating System	Opwglobal	Sitesentinel Integra 500 Firmware	All	All	All	All
Hardware	Opwglobal	Sitesentinel Isite Atg	-	All	All	All
Hardware	Opwglobal	Sitesentinel Isite Atg	-	All	All	All
Operating System	Opwglobal	Sitesentinel Isite Atg Firmware	16q3.1	All	All	All
Operating System	Opwglobal	Sitesentinel Isite Atg Firmware	189	All	All	All
Operating System	Opwglobal	Sitesentinel Isite Atg Firmware	191	All	All	All
Operating System	Opwglobal	Sitesentinel Isite Atg Firmware	195	All	All	All
Operating System	Opwglobal	Sitesentinel Isite Atg Firmware	16q3.1	All	All	All
Operating System	Opwglobal	Sitesentinel Isite Atg Firmware	189	All	All	All
Operating System	Opwglobal	Sitesentinel Isite Atg Firmware	191	All	All	All
Operating System	Opwglobal	Sitesentinel Isite Atg Firmware	195	All	All	All
Operating System	Opwglobal	Sitesentinel Isite Atg Firmware	All	All	All	All

References

Reference	Source	Link	Tag
OPW Fuel Management Systems SiteSentinel Integra and SiteSentinel iSite ICS-CERT	MISC	ics-cert.us-cert.gov	Mit
Multiple OPW Products ICESA-17-243-04 SQL Injection and Authentication Bypass Vulnerabilities	BID	www.securityfocus.com	Thi
CVE Program record	CVE.ORG	www.cve.org	car
NVD vulnerability detail	NVD	nvd.nist.gov	car

No vendor comments have been submitted for this CVE.

There are currently no legacy QID mappings associated with this CVE.