



CVE-2017-5161

[MITRE](#)[NVD](#)[CVE.ORG](#)[JSON API](#)[Print: PDF](#)

Summary

CVE	CVE-2017-5161
State	PUBLIC
Assigner	ics-cert@hq.dhs.gov
Source Priority	CVE Program / NVD first with legacy fallback
Published	2017-02-13 21:59:00 UTC
Updated	2017-03-15 17:44:00 UTC
Description	An issue was discovered in Sielco Sistemi Winlog Lite SCADA Software, versions prior to Version 3.02.01, and Winlog Pro

Risk And Classification

Problem Types: CWE-427

NVD Known Affected Configurations (CPE 2.3)

Type	Vendor	Product	Version	Update	Edition	Language
Application	Sielcosistemi	Winlog Lite	All	All	All	All
Application	Sielcosistemi	Winlog Pro	All	All	All	All

References

Reference	Source	Link
Sielco Sistemi Winlog SCADA Software ICS-CERT	MISC	ics-cert.us-cert.gov
Sielco Sistemi Winlog Pro/ Winlog Lite CVE-2017-5161 DLL Loading Local Code Execution Vulnerability	BID	www.securityfocus.co
CVE Program record	CVE.ORG	www.cve.org
NVD vulnerability detail	NVD	nvd.nist.gov

No vendor comments have been submitted for this CVE.

Legacy QID Mappings

[590964](#) Sielco Sistemi Winlog SCADA Software Uncontrolled Search Path Element Vulnerability (ICSA-17-038-01)

this information or its use. Any use of this information is at the user's risk. It is the responsibility of user to evaluate the accuracy, completeness or usefulness of any information, opinion, advice or other content. EACH USER WILL BE SOLELY RESPONSIBLE FOR ANY consequences of his or her direct or indirect use of this web site. ALL WARRANTIES OF ANY KIND ARE EXPRESSLY DISCLAIMED. This site will NOT BE LIABLE FOR ANY DIRECT, INDIRECT or any other kind of loss.

CVE, CWE, and OVAL are registered trademarks of [The MITRE Corporation](#) and the authoritative source of CVE content is [MITRE's CVE web site](#). This site includes MITRE data granted under the following [license](#).

Free CVE JSON API cve.report/api

CVE.report and Source URL Uptime Status status.cve.report