



CVE-2017-7905

[MITRE](#)[NVD](#)[CVE.ORG](#)[JSON API](#)[Print: PDF](#)

Summary

CVE	CVE-2017-7905
State	PUBLIC
Assigner	ics-cert@hq.dhs.gov
Source Priority	CVE Program / NVD first with legacy fallback
Published	2017-06-30 03:29:00 UTC
Updated	2019-10-09 23:29:00 UTC
Description	A Weak Cryptography for Passwords issue was discovered in General Electric (GE) Multilin SR 750 Feeder Protection Relays.

Risk And Classification

Problem Types: CWE-326 | CWE-330 | CWE-522

NVD Known Affected Configurations (CPE 2.3)

Type	Vendor	Product	Version	Update	Edition	Language
Hardware	Ge	Multilin Sr 369 Motor Protection Relay	-	All	All	All
Hardware	Ge	Multilin Sr 369 Motor Protection Relay	-	All	All	All
Operating System	Ge	Multilin Sr 369 Motor Protection Relay Firmware	-	All	All	All
Operating System	Ge	Multilin Sr 369 Motor Protection Relay Firmware	-	All	All	All
Hardware	Ge	Multilin Sr 469 Motor Protection Relay	-	All	All	All
Hardware	Ge	Multilin Sr 469 Motor Protection Relay	-	All	All	All
Operating System	Ge	Multilin Sr 469 Motor Protection Relay Firmware	All	All	All	All
Hardware	Ge	Multilin Sr 489 Generator Protection Relay	-	All	All	All
Hardware	Ge	Multilin Sr 489 Generator Protection Relay	-	All	All	All
Operating System	Ge	Multilin Sr 489 Generator Protection Relay Firmware	All	All	All	All
Hardware	Ge	Multilin Sr 745 Transformer Protection Relay	-	All	All	All
Hardware	Ge	Multilin Sr 745 Transformer Protection Relay	-	All	All	All
Operating System	Ge	Multilin Sr 745 Transformer Protection Relay Firmware	All	All	All	All
Hardware	Ge	Multilin Sr 750 Feeder Protection Relay	-	All	All	All
Hardware	Ge	Multilin Sr 750 Feeder Protection Relay	-	All	All	All
Operating System	Ge	Multilin Sr 750 Feeder Protection Relay Firmware	All	All	All	All
Hardware	Ge	Multilin Sr 760 Feeder Protection Relay	-	All	All	All

Hardware	Ge	Multilin Sr 760 Feeder Protection Relay	-	All	All	All
Operating System	Ge	Multilin Sr 760 Feeder Protection Relay Firmware	All	All	All	All
Hardware	Ge	Multilin Universal Relay	-	All	All	All
Hardware	Ge	Multilin Universal Relay	-	All	All	All
Operating System	Ge	Multilin Universal Relay Firmware	All	All	All	All
Hardware	Ge	Multilin Urplus B95	-	All	All	All
Hardware	Ge	Multilin Urplus B95	-	All	All	All
Operating System	Ge	Multilin Urplus B95 Firmware	-	All	All	All
Operating System	Ge	Multilin Urplus B95 Firmware	-	All	All	All
Hardware	Ge	Multilin Urplus C90	-	All	All	All
Hardware	Ge	Multilin Urplus C90	-	All	All	All
Operating System	Ge	Multilin Urplus C90 Firmware	-	All	All	All
Operating System	Ge	Multilin Urplus C90 Firmware	-	All	All	All
Hardware	Ge	Multilin Urplus D90	-	All	All	All
Hardware	Ge	Multilin Urplus D90	-	All	All	All
Operating System	Ge	Multilin Urplus D90 Firmware	-	All	All	All
Operating System	Ge	Multilin Urplus D90 Firmware	-	All	All	All

References			
Reference	Source	Link	Tags
ICS-CERT Advisories ICS-CERT	MISC	ics-cert.us-cert.gov	Patch, Third Party Adv
GE Multiple Products CVE-2017-7905 Weak Password Security Vulnerability	BID	www.securityfocus.com	Third Party Advisory, V
CVE Program record	CVE.ORG	www.cve.org	canonical
NVD vulnerability detail	NVD	nvd.nist.gov	canonical, analysis

No vendor comments have been submitted for this CVE.

There are currently no legacy QID mappings associated with this CVE.

