



# CVE-2017-9946

[MITRE](#)[NVD](#)[CVE.ORG](#)[Print: PDF !\[\]\(e3f8612927870f2e0f9f5989e6dd3064\_img.jpg\)](#)

## Summary

<b>CVE</b>	CVE-2017-9946
<b>State</b>	PUBLIC
<b>Assigner</b>	productcert@siemens.com
<b>Source Priority</b>	CVE Program / NVD first with legacy fallback
<b>Published</b>	2017-10-23 08:29:00 UTC
<b>Updated</b>	2023-05-09 16:27:00 UTC
<b>Description</b>	A vulnerability has been identified in Siemens APOGEE PXC and TALON TC BACnet Automation Controllers in all versions

## Risk And Classification

**Problem Types:** CWE-287

## NVD Known Affected Configurations (CPE 2.3)

Type	Vendor	Product	Version	Update	Edition	Language
Hardware	Siemens	Apogee Pxc	-	All	All	All
Hardware	Siemens	Apogee Pxc Bacnet Automation Controller	-	All	All	All
Hardware	Siemens	Apogee Pxc Bacnet Automation Controller	-	All	All	All
Operating System	Siemens	Apogee Pxc Bacnet Automation Controller Firmware	All	All	All	All
Operating System	Siemens	Apogee Pxc Bacnet Automation Controller Firmware	All	All	All	All
Operating System	Siemens	Apogee Pxc Firmware	All	All	All	All
Hardware	Siemens	Apogee Pxc Modular	-	All	All	All
Operating System	Siemens	Apogee Pxc Modular Firmware	All	All	All	All
Hardware	Siemens	Talon Tc Bacnet Automation Controller	-	All	All	All
Hardware	Siemens	Talon Tc Bacnet Automation Controller	-	All	All	All
Operating System	Siemens	Talon Tc Bacnet Automation Controller Firmware	All	All	All	All
Operating System	Siemens	Talon Tc Bacnet Automation Controller Firmware	All	All	All	All
Hardware	Siemens	Talon Tc Compact	-	All	All	All
Operating System	Siemens	Talon Tc Compact Firmware	All	All	All	All
Hardware	Siemens	Talon Tc Modular	-	All	All	All
Operating System	Siemens	Talon Tc Modular Firmware	All	All	All	All

References			
Reference	Source	Link	Tags
Siemens	CONFIRM	<a href="http://www.siemens.com">www.siemens.com</a>	Vendor A
<a href="http://cert-portal.siemens.com/productcert/pdf/ssa-148078.pdf">cert-portal.siemens.com/productcert/pdf/ssa-148078.pdf</a>	CONFIRM	<a href="http://cert-portal.siemens.com">cert-portal.siemens.com</a>	
Siemens APOGEE PXC / TALON TC Authentication Bypass ≈ Packet Storm	MISC	<a href="http://packetstormsecurity.com">packetstormsecurity.com</a>	
Multiple Siemens Products Authentication Bypass and Directory Traversal Vulnerabilities	BID	<a href="http://www.securityfocus.com">www.securityfocus.com</a>	Third Part
CVE Program record	CVE.ORG	<a href="http://www.cve.org">www.cve.org</a>	canonical
NVD vulnerability detail	NVD	<a href="http://nvd.nist.gov">nvd.nist.gov</a>	canonical

No vendor comments have been submitted for this CVE.

### Legacy QID Mappings

[590915](#) Siemens BACnet Field Panels (Update A) Multiple Vulnerabilities (ICSA-17-285-05) (ssa-148078)

© [CVE.report](#) 2026 |

Use of this information constitutes acceptance for use in an AS IS condition. There are NO warranties, implied or otherwise, with regard to this information or its use. Any use of this information is at the user's risk. It is the responsibility of user to evaluate the accuracy, completeness or usefulness of any information, opinion, advice or other content. EACH USER WILL BE SOLELY RESPONSIBLE FOR ANY consequences of his or her direct or indirect use of this web site. ALL WARRANTIES OF ANY KIND ARE EXPRESSLY DISCLAIMED. This site will NOT BE LIABLE FOR ANY DIRECT, INDIRECT or any other kind of loss.

CVE, CWE, and OVAL are registered trademarks of [The MITRE Corporation](#) and the authoritative source of CVE content is [MITRE's CVE web site](#). This site includes MITRE data granted under the following [license](#).

**CVE.report and Source URL Uptime Status** [status.cve.report](http://status.cve.report)