



CVE-2018-17911

[MITRE](#)[NVD](#)[CVE.ORG](#)[JSON API](#)[Print: PDF](#)

Summary

CVE	CVE-2018-17911
State	PUBLIC
Assigner	ics-cert@hq.dhs.gov
Source Priority	CVE Program / NVD first with legacy fallback
Published	2018-10-17 02:29:00 UTC
Updated	2020-09-18 17:24:00 UTC
Description	LAquis SCADA Versions 4.1.0.3870 and prior has several stack-based buffer overflow vulnerabilities, which may allow remote

Risk And Classification

Problem Types: CWE-787

NVD Known Affected Configurations (CPE 2.3)

Type	Vendor	Product	Version	Update	Edition	Language
Application	Lcds	Laquis Scada	All	All	All	All

References

Reference	Source	Link
ZDI-18-1258 Zero Day Initiative	MISC	www.zerodayinitiative.com
LCDS – Leão Consultoria e Desenvolvimento de Sistemas Ltda ME LAquis SCADA ICS-CERT	MISC	ics-cert.us-cert.gov
Install LAquis SCADA software	MISC	laquisscada.com
CVE Program record	CVE.ORG	www.cve.org
NVD vulnerability detail	NVD	nvd.nist.gov

No vendor comments have been submitted for this CVE.

Legacy QID Mappings

[590866](#) LCDS LAquis SCADA Multiple Vulnerabilities (ICSA-18-289-01)

this information or its use. Any use of this information is at the user's risk. It is the responsibility of user to evaluate the accuracy, completeness or usefulness of any information, opinion, advice or other content. EACH USER WILL BE SOLELY RESPONSIBLE FOR ANY consequences of his or her direct or indirect use of this web site. ALL WARRANTIES OF ANY KIND ARE EXPRESSLY DISCLAIMED. This site will NOT BE LIABLE FOR ANY DIRECT, INDIRECT or any other kind of loss.

CVE, CWE, and OVAL are registered trademarks of [The MITRE Corporation](#) and the authoritative source of CVE content is [MITRE's CVE web site](#). This site includes MITRE data granted under the following [license](#).

Free CVE JSON API [cve.report/api](#)

CVE.report and Source URL Uptime Status [status.cve.report](#)