



CVE-2018-7246

[MITRE](#)[NVD](#)[CVE.ORG](#)[JSON API](#)[Print: PDF](#)

Summary

CVE	CVE-2018-7246
State	PUBLIC
Assigner	cybersecurity@schneider-electric.com
Source Priority	CVE Program / NVD first with legacy fallback
Published	2018-04-18 20:29:00 UTC
Updated	2019-10-03 00:03:00 UTC
Description	A cleartext transmission of sensitive information vulnerability exists in Schneider Electric's 66074 MGE Network Manageme

Risk And Classification

Problem Types: CWE-319

NVD Known Affected Configurations (CPE 2.3)

Type	Vendor	Product	Version	Update	Edition	Language
Hardware	Schneider-electric	66074 Mge Network Management Card Transverse	-	All	All	All
Hardware	Schneider-electric	66074 Mge Network Management Card Transverse	-	All	All	All
Hardware	Schneider-electric	Mge Comet Ups	-	All	All	All
Hardware	Schneider-electric	Mge Comet Ups	-	All	All	All
Hardware	Schneider-electric	Mge Eps 6000	-	All	All	All
Hardware	Schneider-electric	Mge Eps 6000	-	All	All	All
Hardware	Schneider-electric	Mge Eps 7000	-	All	All	All
Hardware	Schneider-electric	Mge Eps 7000	-	All	All	All
Hardware	Schneider-electric	Mge Eps 8000	-	All	All	All
Hardware	Schneider-electric	Mge Eps 8000	-	All	All	All
Hardware	Schneider-electric	Mge Galaxy 3000	-	All	All	All
Hardware	Schneider-electric	Mge Galaxy 3000	-	All	All	All
Hardware	Schneider-electric	Mge Galaxy 4000	-	All	All	All
Hardware	Schneider-electric	Mge Galaxy 4000	-	All	All	All
Hardware	Schneider-electric	Mge Galaxy 5000	-	All	All	All
Hardware	Schneider-electric	Mge Galaxy 5000	-	All	All	All
Hardware	Schneider-electric	Mge Galaxy 6000	-	All	All	All

Hardware	Schneider-electric	Mge Galaxy 6000	-	All	All	All
Hardware	Schneider-electric	Mge Galaxy 9000	-	All	All	All
Hardware	Schneider-electric	Mge Galaxy 9000	-	All	All	All
Hardware	Schneider-electric	Mge Galaxy Pw	-	All	All	All
Hardware	Schneider-electric	Mge Galaxy Pw	-	All	All	All

References

Reference	Source
Security Notification— 66074 MGE Network Management Card Transverse installed in MGE UPS and MGE STS Schneider Electric	CONF
CVE Program record	CVE.C
NVD vulnerability detail	NVD



No vendor comments have been submitted for this CVE.

Legacy QID Mappings

[591080](#) Schneider Electric MGE Network Management Card Transverse installed in MGE UPS and MGE STS Multiple Vulnerabilities (SEVD-2018-074-01)