




CVE-2018-7796

Published on: 12/24/2018 12:00:00 AM UTC

Last Modified on: 03/23/2021 11:24:39 PM UTC

CVE-2018-7796

[Source: Mitre](#)[Source: NIST](#)[CVE.ORG](#)[Print: PDF](#) 

Certain versions of [Powersuite 2](#) from [Schneider-electric](#) contain the following vulnerability:

A Buffer Error vulnerability exists in PowerSuite 2, all released versions (VW3A8104 & Patches), which could cause an overflow in the memcpy function, leading to corruption of data and program instability.

CVE-2018-7796 has been assigned by [cybersecurity@schneider-electric.com](#) to track the vulnerability - currently rated as **MEDIUM** severity.

Affected Vendor/Software: [Schneider Electric SE - PowerSuite 2, All released versions \(VW3A8104 & Patches\)](#) version **PowerSuite 2, All released versions (VW3A8104 & Patches)**

CVSS3 Score: **6.3 - MEDIUM**

Attack Vector	Attack Complexity	Privileges Required	User Interaction
NETWORK	LOW	NONE	REQUIRED
Scope	Confidentiality Impact	Integrity Impact	Availability Impact
UNCHANGED	LOW	LOW	LOW

CVSS2 Score: **6.8 - MEDIUM**

Access Vector	Access Complexity	Authentication
NETWORK	MEDIUM	NONE
Confidentiality Impact	Integrity Impact	Availability Impact
PARTIAL	PARTIAL	PARTIAL

CVE References

Description	Tags	Link
Security Notification - PowerSuite 2	Vendor Advisory	CONFIRM www.schneider-

Security Remediation - Powersuite 2 | Schneider Electric

Vendor Address

www.schneider-electric.com

[text/html](#)

CVE ID

[electric.com/en/download/document/SEVD-2018-351-01/](http://www.schneider-electric.com/en/download/document/SEVD-2018-351-01/)

By selecting these links, you may be leaving CVEreport webspace. We have provided these links to other websites because they may have information that would be of interest to you. No inferences should be drawn on account of other sites being referenced, or not, from this page. There may be other websites that are more appropriate for your purpose. CVEreport does not necessarily endorse the views expressed, or concur with the facts presented on these sites. Further, CVEreport does not endorse any commercial products that may be mentioned on these sites. Please address comments about any linked pages to comment@cve.report.

There are currently no QIDs associated with this CVE

Known Affected Configurations (CPE V2.3)

Type	Vendor	Product	Version	Update	Edition	Language
Application	Schneider-electric	Powersuite 2	All	All	All	All
Application	Schneider-electric	Powersuite 2	All	All	All	All

cpe:2.3:a:schneider-electric:powersuite_2:*****::

cpe:2.3:a:schneider-electric:powersuite_2:*****::

No vendor comments have been submitted for this CVE

← Previous ID

Next ID →