




CVE-2018-7834

Published on: 05/22/2019 12:00:00 AM UTC

Last Modified on: 03/23/2021 11:24:37 PM UTC

CVE-2018-7834

[Source: Mitre](#)[Source: NIST](#)[CVE.ORG](#)[Print: PDF](#) 

Certain versions of [Tsxetg100](#) from [Schneider-electric](#) contain the following vulnerability:

A CWE-79 Cross-Site Scripting vulnerability exists in all versions of the TSXETG100 allowing an attacker to send a specially crafted URL with an embedded script to a user that would then be executed within the context of that user.

CVE-2018-7834 has been assigned by [cybersecurity@schneider-electric.com](#) to track the vulnerability - currently rated as **MEDIUM** severity.

CVSS3 Score: **6.1 - MEDIUM**

Attack Vector	Attack Complexity	Privileges Required	User Interaction
NETWORK	LOW	NONE	REQUIRED
Scope	Confidentiality Impact	Integrity Impact	Availability Impact
CHANGED	LOW	LOW	NONE

CVSS2 Score: **4.3 - MEDIUM**

Access Vector	Access Complexity	Authentication
NETWORK	MEDIUM	NONE
Confidentiality Impact	Integrity Impact	Availability Impact
NONE	PARTIAL	NONE

CVE References

Description	Tags	Link
Security Notification - ConneXium Gateway & PowerLogic Ethernet Gateway (V2) Schneider Electric	Vendor Advisory www.schneider-electric.com text/html	MISC www.schneider-electric.com/en/download/document/SEVD-2019-134-07/

By selecting these links, you may be leaving CVEreport webspace. We have provided these links to other websites because they may have information that would be of interest to you. No inferences should be drawn on account of other sites being referenced, or not, from this page. There may be other websites that are more appropriate for your purpose. CVEreport does not necessarily endorse the views expressed, or concur with the facts presented on these sites. Further, CVEreport does not endorse any commercial products that may be mentioned on these sites. Please address comments about any linked pages to comment@cve.report.

Related QID Numbers

590864 Schneider Electric ConneXium Gateway TSXETG100 and PowerLogic Ethernet Gateway EGX100 (V2) Vulnerability (SEVD-2019-134-07)

Known Affected Configurations (CPE V2.3)

Type	Vendor	Product	Version	Update	Edition	Language
Hardware 	Schneider-electric	Tsxetg100	-	All	All	All
Hardware 	Schneider-electric	Tsxetg100	-	All	All	All
Operating System	Schneider-electric	Tsxetg100 Firmware	All	All	All	All
Operating System	Schneider-electric	Tsxetg100 Firmware	All	All	All	All
cpe:2.3:h:schneider-electric:tsxetg100:-:~::~~::~~::~~::~~::~~::~~:::						
cpe:2.3:h:schneider-electric:tsxetg100:-:~::~~::~~::~~::~~::~~::~~:::						
cpe:2.3:o:schneider-electric:tsxetg100_firmware:~::~~::~~::~~::~~::~~::~~:::						
cpe:2.3:o:schneider-electric:tsxetg100_firmware:~::~~::~~::~~::~~::~~::~~:::						

No vendor comments have been submitted for this CVE

← Previous ID

Next ID →