



CVE-2020-28210

[MITRE](#)[NVD](#)[CVE.ORG](#)[Print: PDF](#)

Summary

CVE	CVE-2020-28210
State	PUBLIC
Assigner	cybersecurity@schneider-electric.com
Source Priority	CVE Program / NVD first with legacy fallback
Published	2020-11-19 21:15:00 UTC
Updated	2022-01-31 19:33:00 UTC
Description	A CWE-79 Improper Neutralization of Input During Web Page Generation (Cross-site Scripting) vulnerability exists in EcoSt

Risk And Classification

Problem Types: CWE-79

NVD Known Affected Configurations (CPE 2.3)

Type	Vendor	Product	Version	Update	Edition	Language
Application	Schneider-electric	Ecostruxure Building Operation	All	All	All	All
Application	Se	Ecostruxure Building Operation	All	All	All	All

References

Reference	Source	Link	Tags
Security Notification - EcoStruxure™ Building Operation (EBO) Schneider Electric	MISC	www.se.com	Vendor Advisory
CVE Program record	CVE.ORG	www.cve.org	canonical
NVD vulnerability detail	NVD	nvd.nist.gov	canonical, analysis

No vendor comments have been submitted for this CVE.

There are currently no legacy QID mappings associated with this CVE.

CVE, CWE, and OVAL are registered trademarks of [The MITRE Corporation](#) and the authoritative source of CVE content is [MITRE's CVE web site](#). This site includes MITRE data granted under the following [license](#).

CVE.report and Source URL Uptime Status [status.cve.report](#)