



CVE-2020-7494

Published on: 06/16/2020 12:00:00 AM UTC

Last Modified on: 03/23/2021 11:23:53 PM UTC


CVE-2020-7494

Source: Mitre

Source: NIST

CVE.ORG

Print: PDF



Certain versions of [Ecostruxure Operator Terminal Expert](#) from [Schneider-electric](#) contain the following vulnerability:

A CWE-22: Improper Limitation of a Pathname to a Restricted Directory ('Path Traversal') vulnerability exists in EcoStruxure Operator Terminal Expert 3.1 Service Pack 1 and prior (formerly known as Vijeo XD) which could cause malicious code execution when opening the project file.

CVE-2020-7494 has been assigned by cybersecurity@schneider-electric.com to track the vulnerability - currently rated as **HIGH** severity.

CVSS3 Score: **7.8 - HIGH**

Attack Vector	Attack Complexity	Privileges Required	User Interaction
LOCAL	LOW	NONE	REQUIRED
Scope	Confidentiality Impact	Integrity Impact	Availability Impact
UNCHANGED	HIGH	HIGH	HIGH

CVSS2 Score: **6.8 - MEDIUM**

Access Vector	Access Complexity	Authentication
NETWORK	MEDIUM	NONE
Confidentiality Impact	Integrity Impact	Availability Impact
PARTIAL	PARTIAL	PARTIAL

CVE References

Description	Tags	Link
EcoStruxure™ Operator Terminal Expert (Vijeo XD) (V2) Schneider Electric	Vendor Advisory www.se.com	MISC www.se.com/ww/en/download/document/SEVD-2020-122-04

There are currently no QIDs associated with this CVE

Type	Vendor	Product	Version	Update	Edition	Language
Application	Schneider-electric	Ecostruxure Operator Terminal Expert	3.1	-	All	All
Application	Schneider-electric	Ecostruxure Operator Terminal Expert	3.1	sp1	All	All
Application	Schneider-electric	Ecostruxure Operator Terminal Expert	3.1	-	All	All
Application	Schneider-electric	Ecostruxure Operator Terminal Expert	3.1	sp1	All	All
Application	Schneider-electric	Ecostruxure Operator Terminal Expert	All	All	All	All
cpe:2.3:a:schneider-electric:ecostruxure_operator_terminal_expert:3.1:-:*:*:*:*:*:						
cpe:2.3:a:schneider-electric:ecostruxure_operator_terminal_expert:3.1:sp1:*:*:*:*:*:						
cpe:2.3:a:schneider-electric:ecostruxure_operator_terminal_expert:3.1:-:*:*:*:*:*:						
cpe:2.3:a:schneider-electric:ecostruxure_operator_terminal_expert:3.1:sp1:*:*:*:*:*:						
cpe:2.3:a:schneider-electric:ecostruxure_operator_terminal_expert:*:*:*:*:*:*:						

Next ID→