



CVE-2020-7570

Published on: 11/19/2020 12:00:00 AM UTC

Last Modified on: 01/31/2022 07:45:00 PM UTC


CVE-2020-7570

Source: Mitre

Source: NIST

CVE.ORG

Print: PDF



Certain versions of [Webreports](#) from [Schneider-electric](#) contain the following vulnerability:

A CWE-79 Improper Neutralization of Input During Web Page Generation (Cross-site Scripting Stored) vulnerability exists in EcoStruxure Building Operation WebReports V1.9 - V3.1 that could cause an authenticated remote user being able to inject arbitrary web script or HTML due to incorrect sanitization of user-supplied data and achieve a Cross-Site Scripting stored attack against other WebReport users.

CVE-2020-7570 has been assigned by cybersecurity@schneider-electric.com to track the vulnerability - currently rated as **MEDIUM** severity.

CVSS3 Score: **5.4 - MEDIUM**

Attack Vector	Attack Complexity	Privileges Required	User Interaction
NETWORK	LOW	LOW	REQUIRED
Scope	Confidentiality Impact	Integrity Impact	Availability Impact
CHANGED	LOW	LOW	NONE

CVSS2 Score: **3.5 - LOW**

Access Vector	Access Complexity	Authentication
NETWORK	MEDIUM	SINGLE
Confidentiality Impact	Integrity Impact	Availability Impact
NONE	PARTIAL	NONE

CVE References

Description	Tags	Link
Security Notification - EcoStruxure™ Building Operation (EBO)	Patch	MISC

By selecting these links, you may be leaving CVEreport webspace. We have provided these links to other websites because they may have information that would be of interest to you. No inferences should be drawn on account of other sites being referenced, or not, from this page. There may be other websites that are more appropriate for your purpose. CVEreport does not necessarily endorse the views expressed, or concur with the facts presented on these sites. Further, CVEreport does not endorse any commercial products that may be mentioned on these sites. Please address comments about any linked pages to comment@cve.report.

There are currently no QIDs associated with this CVE

Known Affected Configurations (CPE V2.3)

Type	Vendor	Product	Version	Update	Edition	Language
Application	Schneider-electric	Webreports	All	All	All	All
Application	Se	Webreports	All	All	All	All

cpe:2.3:a:schneider-electric:webreports:*:*:*:*:*:*:

cpe:2.3:a:se:webreports:*:*:*:*:*:*:

No vendor comments have been submitted for this CVE

[← Previous ID](#)

[Next ID →](#)