



CVE-2021-33003

[MITRE](#)[NVD](#)[CVE.ORG](#)[JSON API](#)[Print: PDF](#)

Summary

CVE	CVE-2021-33003
State	PUBLIC
Assigner	ics-cert@hq.dhs.gov
Source Priority	CVE Program / NVD first with legacy fallback
Published	2021-08-30 18:15:00 UTC
Updated	2021-09-03 14:13:00 UTC
Description	Delta Electronics DIAEnergie Version 1.7.5 and prior may allow an attacker to retrieve passwords in cleartext due to a weak

Risk And Classification

Problem Types: CWE-327

NVD Known Affected Configurations (CPE 2.3)

Type	Vendor	Product	Version	Update	Edition	Language
Application	Deltaww	Diaenergie	All	All	All	All

References

Reference	Source	Link	Tags
Delta Electronics DIAEnergie CISA	MISC	us-cert.cisa.gov	
CVE Program record	CVE.ORG	www.cve.org	canonical
NVD vulnerability detail	NVD	nvd.nist.gov	canonical, analysis

No vendor comments have been submitted for this CVE.

Legacy QID Mappings

[591094](#) Delta Electronics DIAEnergie (Update C) Multiple Vulnerabilities (ICSA-21-238-03)

CVE, CWE, and OVAL are registered trademarks of [The MITRE Corporation](#) and the authoritative source of CVE content is [MITRE's CVE web site](#). This site includes MITRE data granted under the following [license](#).

Free CVE JSON API cve.report/api

CVE.report and Source URL Uptime Status status.cve.report