



CVE-2021-35527

[MITRE](#)[NVD](#)[CVE.ORG](#)[Print: PDF](#)

Summary

CVE	CVE-2021-35527
State	PUBLIC
Assigner	cybersecurity@hitachi-powergrids.com
Source Priority	CVE Program / NVD first with legacy fallback
Published	2021-07-14 14:15:00 UTC
Updated	2023-05-16 20:21:00 UTC
Description	Password autocomplete vulnerability in the web application password field of Hitachi ABB Power Grids eSOMS allows attac

Risk And Classification

Problem Types: CWE-522

NVD Known Affected Configurations (CPE 2.3)

Type	Vendor	Product	Version	Update	Edition	Language
Application	Abb	Esoms	All	All	All	All
Application	Hitachienergy	Esoms	All	All	All	All

References

Reference	Source	Link	Tags
search.abb.com/library/Download.aspx	CONFIRM	search.abb.com	
CVE Program record	CVE.ORG	www.cve.org	canonical
NVD vulnerability detail	NVD	nvd.nist.gov	canonical, analysis

No vendor comments have been submitted for this CVE.

There are currently no legacy QID mappings associated with this CVE.

CVE, CWE, and OVAL are registered trademarks of [The MITRE Corporation](#) and the authoritative source of CVE content is [MITRE's CVE web site](#). This site includes MITRE data granted under the following [license](#).

CVE.report and Source URL Uptime Status [status.cve.report](#)