



CVE-2022-1778

[MITRE](#)[NVD](#)[CVE.ORG](#)[Print: PDF](#)

Summary

CVE	CVE-2022-1778
State	PUBLIC
Assigner	cybersecurity@hitachienergy.com
Source Priority	CVE Program / NVD first with legacy fallback
Published	2022-09-14 18:15:00 UTC
Updated	2023-06-27 15:47:00 UTC
Description	Improper Input Validation vulnerability in Hitachi Energy MicroSCADA X SYS600 while reading a specific configuration file c

Risk And Classification

Problem Types: CWE-119

NVD Known Affected Configurations (CPE 2.3)

Type	Vendor	Product	Version	Update	Edition	Language
Application	Hitachi	Microscada X Sys600	All	All	All	All
Hardware	Hitachi	Sys600	-	All	All	All
Application	Hitachienergy	Microscada X Sys600	All	All	All	All
Hardware	Hitachienergy	Sys600	-	All	All	All

References

Reference	Source	Link	Tags
search.abb.com/library/Download.aspx	CONFIRM	search.abb.com	
CVE Program record	CVE.ORG	www.cve.org	canonical
NVD vulnerability detail	NVD	nvd.nist.gov	canonical, analysis

No vendor comments have been submitted for this CVE.

There are currently no legacy QID mappings associated with this CVE.

completeness or usefulness of any information, opinion, advice or other content. EACH USER WILL BE SOLELY RESPONSIBLE FOR ANY consequences of his or her direct or indirect use of this web site. ALL WARRANTIES OF ANY KIND ARE EXPRESSLY DISCLAIMED. This site will NOT BE LIABLE FOR ANY DIRECT, INDIRECT or any other kind of loss.

CVE, CWE, and OVAL are registered trademarks of [The MITRE Corporation](#) and the authoritative source of CVE content is [MITRE's CVE web site](#). This site includes MITRE data granted under the following [license](#).

CVE.report and Source URL Uptime Status [status.cve.report](#)