



CVE-2022-30316

[MITRE](#)[NVD](#)[CVE.ORG](#)[Print: PDF !\[\]\(e3f8612927870f2e0f9f5989e6dd3064_img.jpg\)](#)

Summary

| | |
|------------------------|---|
| CVE | CVE-2022-30316 |
| State | PUBLIC |
| Assigner | cve@mitre.org |
| Source Priority | CVE Program / NVD first with legacy fallback |
| Published | 2022-07-28 16:15:00 UTC |
| Updated | 2022-08-05 22:31:00 UTC |
| Description | Honeywell Experion PKS Safety Manager 5.02 has Insufficient Verification of Data Authenticity. According to FSCT-2022-0 |

Risk And Classification

Problem Types: CWE-354

NVD Known Affected Configurations (CPE 2.3)

| Type | Vendor | Product | Version | Update | Edition | Language |
|------------------|-----------|-------------------------|---------|--------|---------|----------|
| Hardware | Honeywell | Safety Manager | - | All | All | All |
| Operating System | Honeywell | Safety Manager Firmware | - | All | All | All |

References

| Reference | Source | Link | Tags |
|---------------------------------|---------|--|---------------------|
| Honeywell Safety Manager CISA | MISC | www.cisa.gov | |
| Blog - Forescout | MISC | www.forescout.com | |
| CVE Program record | CVE.ORG | www.cve.org | canonical |
| NVD vulnerability detail | NVD | nvd.nist.gov | canonical, analysis |

No vendor comments have been submitted for this CVE.

There are currently no legacy QID mappings associated with this CVE.

site will NOT BE LIABLE FOR ANY DIRECT, INDIRECT or any other kind of loss.

CVE, CWE, and OVAL are registered trademarks of [The MITRE Corporation](#) and the authoritative source of CVE content is [MITRE's CVE web site](#). This site includes MITRE data granted under the following [license](#).

CVE.report and Source URL Uptime Status [status.cve.report](#)