



# CVE-2022-32529

[MITRE](#)[NVD](#)[CVE.ORG](#)[JSON API](#)[Print: PDF](#)

## Summary

<b>CVE</b>	CVE-2022-32529
<b>State</b>	PUBLIC
<b>Assigner</b>	cybersecurity@schneider-electric.com
<b>Source Priority</b>	CVE Program / NVD first with legacy fallback
<b>Published</b>	2023-01-30 23:15:00 UTC
<b>Updated</b>	2023-02-08 17:47:00 UTC
<b>Description</b>	A CWE-120: Buffer Copy without Checking Size of Input vulnerability exists that could cause a stack-based buffer overflow,

## Risk And Classification

**Problem Types:** CWE-120

## NVD Known Affected Configurations (CPE 2.3)

Type	Vendor	Product	Version	Update	Edition	Language
Application	<a href="#">Schneider-electric</a>	<a href="#">Igss Data Server</a>	All	All	All	All
Application	<a href="#">Schneider-electric</a>	<a href="#">Interactive Graphical Scada System</a>	All	All	All	All

## References

Reference	Source	Link	Tags
<a href="#">download.schneider-electric.com/files</a>	MISC	<a href="#">download.schneider-electric.com</a>	
CVE Program record	CVE.ORG	<a href="#">www.cve.org</a>	canonical
NVD vulnerability detail	NVD	<a href="#">nvd.nist.gov</a>	canonical, analysis

No vendor comments have been submitted for this CVE.

## Legacy QID Mappings

[591046](#) Schneider Electric IGSS Multiple Vulnerabilities (SEVD-2022-165-01 V2.0)

site will NOT BE LIABLE FOR ANY DIRECT, INDIRECT or any other kind of loss.

CVE, CWE, and OVAL are registered trademarks of [The MITRE Corporation](#) and the authoritative source of CVE content is [MITRE's CVE web site](#). This site includes MITRE data granted under the following [license](#).

**Free CVE JSON API** [cve.report/api](https://cve.report/api)

**CVE.report and Source URL Uptime Status** [status.cve.report](https://status.cve.report)