



CVE-2023-28654

[MITRE](#)[NVD](#)[CVE.ORG](#)[JSON API](#)[Print: PDF](#)

Summary

CVE	CVE-2023-28654
State	PUBLIC
Assigner	ics-cert@hq.dhs.gov
Source Priority	CVE Program / NVD first with legacy fallback
Published	2023-03-28 21:15:00 UTC
Updated	2023-11-07 04:10:00 UTC
Description	Osprey Pump Controller version 1.01 has a hidden administrative account that has the hardcoded password that allows full

Risk And Classification

Problem Types: CWE-798

NVD Known Affected Configurations (CPE 2.3)

Type	Vendor	Product	Version	Update	Edition	Language
Hardware	Propumpservice	Osprey Pump Controller	-	All	All	All
Operating System	Propumpservice	Osprey Pump Controller Firmware	1.01	All	All	All

References

Reference	Source	Link	Tags
ProPump and Controls Osprey Pump Controller CISA	MISC	www.cisa.gov	
CVE Program record	CVE.ORG	www.cve.org	canonical
NVD vulnerability detail	NVD	nvd.nist.gov	canonical, analysis

No vendor comments have been submitted for this CVE.

There are currently no legacy QID mappings associated with this CVE.

CVE, CWE, and OVAL are registered trademarks of [The MITRE Corporation](#) and the authoritative source of CVE content is [MITRE's CVE web site](#). This site includes MITRE data granted under the following [license](#).

Free CVE JSON API cve.report/api

CVE.report and Source URL Uptime Status status.cve.report