



Multiple implicit reads in parallel can result in a crash or denial of service

[MITRE](#)[NVD](#)[CVE.ORG](#)[Print: PDF](#)

Summary

CVE	CVE-2024-14028
State	PUBLISHED
Assigner	Softing
Source Priority	CVE Program / NVD first with legacy fallback
Published	2026-03-27 06:16:35 UTC
Updated	2026-03-30 13:26:29 UTC
Description	Use after free vulnerability in Softing smartLink HW-DP or smartLink HW-PN webserver allows HTTP DoS. This issue affects

Risk And Classification

Primary CVSS: v3.1 6.5 MEDIUM from 10de8ef9-5c89-4b17-8228-e97b74acf4bd

CVSS: 3.1/AV:N/AC:L/PR:N/UI:R/S:U/C:N/I:N/A:H

EPSS: 0.000370000 probability, percentile 0.110560000 (date 2026-04-02)

Problem Types: CWE-416 | CWE-416 CWE-416 Use after free

Version	Source	Type	Score	Severity	Vector
3.1	10de8ef9-5c89-4b17-8228-e97b74acf4bd	Secondary	6.5	MEDIUM	CVSS:3.1/AV:N/AC:L/PR:N/UI:R/S:U/C:N/I:N/A:H
3.1	CNA	CVSS	6.5	MEDIUM	CVSS:3.1/AV:N/AC:L/PR:N/UI:R/S:U/C:N/I:N/A:H

CVSS v3.1 Breakdown

Attack Vector

Network

Attack Complexity

Low

Privileges Required

None

User Interaction

Required

Scope

Unchanged

Confidentiality

None

Integrity

None

Availability

High

CVSS:3.1/AV:N/AC:L/PR:N/UI:R/S:U/C:N/I:N/A:H

Vendor Declared Affected Products

Source	Vendor	Product	Version	Platforms
CNA	Softing	SmartLink HW-DP	affected 1.31 custom	Not specified
CNA	Softing	SmartLink HW-DP	unaffected 1.32 custom	Not specified
CNA	Softing	SmartLink HW-PN	affected 1.02 custom	Not specified
CNA	Softing	SmartLink HW-PN	unaffected 1.02 custom	Not specified

References

Reference	Source	Link
industrial.softing.com/fileadmin/psirt/downloads/2024/CVE-2024-14028.html	10de8ef9-5c89-4b17-8228-e97b74acf4bd	industrial.softing.co
industrial.softing.com/fileadmin/psirt/downloads/2024/CVE-2024-14028.json	10de8ef9-5c89-4b17-8228-e97b74acf4bd	industrial.softing.co
CVE Program record	CVE.ORG	www.cve.org
NVD vulnerability detail	NVD	nvd.nist.gov

No vendor comments have been submitted for this CVE.

Additional Advisory Data

Solutions

CNA: Update firmware for smartLink HW-DP: to 1.32 smartLink HW-PN: to 1.02.

There are currently no legacy QID mappings associated with this CVE.

© CVE.report 2026 |

Use of this information constitutes acceptance for use in an AS IS condition. There are NO warranties, implied or otherwise, with regard to this information or its use. Any use of this information is at the user's risk. It is the responsibility of user to evaluate the accuracy, completeness or usefulness of any information, opinion, advice or other content. EACH USER WILL BE SOLELY RESPONSIBLE FOR ANY consequences of his or her direct or indirect use of this web site. ALL WARRANTIES OF ANY KIND ARE EXPRESSLY DISCLAIMED. This site will NOT BE LIABLE FOR ANY DIRECT, INDIRECT or any other kind of loss.

CVE, CWE, and OVAL are registered trademarks of [The MITRE Corporation](#) and the authoritative source of CVE content is [MITRE's CVE web site](#). This site includes MITRE data granted under the following [license](#).

CVE.report and Source URL Uptime Status [status.cve.report](#)