Insertion of Sesitive Information into Log File in Hydrosystem Control System

MITRE | NVD | CVE.ORG | JSON API | Print: PDF

Summary

CVE	CVE-2026-4901
State	PUBLISHED
Assigner	CERT-PL
Source Priority	CVE Program / NVD first with legacy fallback
Published	2026-04-09 10:16:22 UTC
Updated	2026-04-20 17:05:29 UTC
Description	Hydrosystem Control System saves sensitive information into a log file. Critically, user credentials are logged allowing the a

Risk And Classification

Primary CVSS: v4.0 6.9 MEDIUM from cvd@cert.pl

CVSS:4.0/AV:N/AC:L/AT:N/PR:H/UI:N/VC:H/VI:N/VA:N/SC:N/SI:N/SA:N/E:X/CR:X/IR:X/AR:X/MAV:X/MAC:X/MAT:X/MPR:X/MUI:X/MVC:X/MVI:X/MVA:X/MSC:X/MSI:X/MSA:X/S:X/AU:X/R:X/V:X/RE:X/U:X

EPSS: 0.000330000 probability, percentile 0.096350000 (date 2026-04-21)

Problem Types: CWE-532 | CWE-532 CWE-532: Insertion of Sensitive Information into Log File

Version	Source	Type	Score	Severity	Vector
4.0	cvd@cert.pl	Secondary	6.9	MEDIUM	CVSS:4.0/AV:N/AC:L/AT:N/PR:H/UI:N/VC:H/VI:N/VA:N/SC:N/SI:N/SA:N/E:X/C...
4.0	CNA	CVSS	6.9	MEDIUM	CVSS:4.0/AV:N/AC:L/AT:N/PR:H/UI:N/VC:H/VI:N/VA:N/SC:N/SI:N/SA:N
3.1	nvd@nist.gov	Primary	6.5	MEDIUM	CVSS:3.1/AV:N/AC:L/PR:L/UI:N/S:U/C:H/I:N/A:N

CVSS v4.0 Breakdown

Attack Vector

Network

Attack Complexity

Low

Attack Requirements

None

Privileges Required

High

User Interaction

None

Confidentiality

High

Integrity

None

Availability

None

Sub Conf.

None

Sub Integrity

None

Sub Availability

None

CVSS:4.0/AV:N/AC:L/AT:N/PR:H/UI:N/VC:H/VI:N/VA:N/SC:N/SI:N/SA:N/E:X/CR:X/IR:X/AR:X/MAV:X/MAC:X/MAT:X/MPR:X/MUI:X/MVC:X/MVI:X/MVA:X/MSC:X/MSI:X/MSA:X/S:X/AU:X/R:X/V:X/RE:X/U:X

CVSS v3.1 Breakdown

Attack Vector

Network

Attack Complexity

Low

Privileges Required

Low

User Interaction

None

Scope

Unchanged

Confidentiality

High

Integrity

None

Availability

None

CVSS:3.1/AV:N/AC:L/PR:L/UI:N/S:U/C:H/I:N/A:N

NVD Known Affected Configurations (CPE 2.3)

Type	Vendor	Product	Version	Update	Edition	Language
Application	Hydrosystem.poznan	Control System	All	All	All	All

Vendor Declared Affected Products

Source	Vendor	Product	Version	Platforms

CNA	Hydrosystem	Control System	affected 9.8.5 semver	Not specified

References

Reference	Source	Link	Tags
cert.pl/posts/2026/04/CVE-2026-4901	cvd@cert.pl	cert.pl	Vendor Advisory
www.hydrosystem.poznan.pl	cvd@cert.pl	www.hydrosystem.poznan.pl	Product
CVE Program record	CVE.ORG	www.cve.org	canonical
NVD vulnerability detail	NVD	nvd.nist.gov	canonical, analysis

Vendor Comments And Credit

Discovery Credit

CNA: Jarosław "Jahrek" Kamiński - Securitum (en)

There are currently no legacy QID mappings associated with this CVE.

© CVE.report 2026 |
Use of this information constitutes acceptance for use in an AS IS condition. There are NO warranties, implied or otherwise, with regard to this information or its use. Any use of this information is at the user's risk. It is the responsibility of user to evaluate the accuracy, completeness or usefulness of any information, opinion, advice or other content. EACH USER WILL BE SOLELY RESPONSIBLE FOR ANY consequences of his or her direct or indirect use of this web site. ALL WARRANTIES OF ANY KIND ARE EXPRESSLY DISCLAIMED. This site will NOT BE LIABLE FOR ANY DIRECT, INDIRECT or any other kind of loss.

CVE, CWE, and OVAL are registred trademarks of The MITRE Corporation and the authoritative source of CVE content is MITRE's CVE web site. This site includes MITRE data granted under the following license.

Free CVE JSON API cve.report/api

CVE.report and Source URL Uptime Status **status.cve.report**